SRI BAALAMURUGAN BOREWELLS

Hennur-Bagalur Road, opp. Vijaya Bank, Kothanur, Bangalore
Mob.: 9845020536, 9901920004

WORK REPORT

To
AEE, Sub-Division, Yelahanka
old Twone Bangalore
Nagenahalli village. Near-water Tank road
ward-2

No. : 406

Date : 10/01/2021

S.No.	Particulars	Rft	Water Yeild	Remarks
1.	Size of the Borewell	6½ Inch dia.		
2.	Total Deapth of the Borewell	1000 Rft		
3.	MS Casing Erected	250 Rft		
4.	1st Water Source at the Deapth	800'	0½"	
5.	2nd Water Source at the Deapth	—	—	
6.	3rd Water Source at the Deapth	—	—	
7.	4th Water Source at the Deapth	—	—	
8.	If any Silt, Boulders at the Deapth	—	—	
9.	Nature of Water	clean	field.	Failed.
10.	Motor Pump to be used	—	—	
11.	Any other Remarks	No		
12.	Total Yeild of the Borewell		½" Inch	

AE-1
A.E.E
AE-2

Thanking You

Yours faithfully

SRI BAALAMURUGAN BOREWELLS

Hennur-Bagalur Road, opp. Vijaya Bank, Kothanur, Bangalore
Mob.: 9845020536, 9901920004

WORK REPORT

To
Ace; Sub Division yelahanka
old. Taluka. Bangalore.
Horohalli Srinidhi layout
ward-02

No. : 402

Date : 21-3-2021

S.No.	Particulars	Rft	Water Yeild	Remarks
1.	Size of the Borewell	6½" dia		
2.	Total Deapth of the Borewell	1220 fts.		
3.	MS Casing Erected	185 fts		
4.	1st Water Source at the Deapth	450'	1"	
5.	2nd Water Source at the Deapth	780'	1"	
6.	3rd Water Source at the Deapth	—	—	
7.	4th Water Source at the Deapth	—	—	
8.	If any Silt, Boulders at the Deapth	—	—	
9.	Nature of Water	clear		
10.	Motor Pump to be used	—	—	
11.	Any other Remarks	— No —		
12.	Total Yeild of the Borewell		2" Inches.	
	A.E.E			
	A.E.E	Asst. Engr		

Thanking You

Yours faithfully
For Sri Baalamurugan Borewells

SRI BAALAMURUGAN BOREWELLS

Hennur-Bagalur Road, opp. Vijaya Bank, Kothanur, Bangalore
Mob.: 9845020536, 9901920004

WORK REPORT

To
Aee. y. Sub Division. Yelahanka
old, Twone.
Harohalli cachen
ward. 02.

No : 403

Date : 21-3-2021

S.No.	Particulars	Rft	Water Yeild	Remarks
1.	Size of the Borewell	6½" dia		
2.	Total Deapth of the Borewell	1049 ft		
3.	MS Casing Erected	200 Rft		
4.	1st Water Source at the Deapth	400'	½"	
5.	2nd Water Source at the Deapth	650'	1"	
6.	3rd Water Source at the Deapth	900	½	
7.	4th Water Source at the Deapth	—	—	
8.	If any Silt, Boulders at the Deapth	—	-	
9.	Nature of Water	Clear		
10.	Motor Pump to be used	—	—	
11.	Any other Remarks	—	—	
12.	Total Yeild of the Borewell		2" Inch	

AE-2

A.E.E

AE-02

Thanking You

Yours faithfully
For Sri Baalamurugan Borewells

SRI BAALAMURUGAN BOREWELLS

Hennur-Bagalur Road, opp. Vijaya Bank, Kothanur, Bangalore
Mob.: 9845020536, 9901920004

WORK REPORT

To
AEE, Sub Division Yelahanka
Old Town.
Sri Ram Apartment. Road.
Bangalore.

No. : 404

Date : 21-03-2021

S.No.	Particulars	Rft	Water Yeild	Remarks
1.	Size of the Borewell	6½ dia		
2.	Total Deapth of the Borewell	1033 RSL		
3.	MS Casing Erected	285"		
4.	1st Water Source at the Deapth	350	1"	
5.	2nd Water Source at the Deapth	800	1½"	
6.	3rd Water Source at the Deapth	—	—	
7.	4th Water Source at the Deapth	—	—	
8.	If any Silt, Boulders at the Deapth	—	—	
9.	Nature of Water	Clear		
10.	Motor Pump to be used	—	—	
11.	Any other Remarks	— No —		
12.	Total Yeild of the Borewell		2" Bore	
	AE-D			
	A.E.E AE-02			

Thanking You

Yours faithfully
For Sri Baalamurugan Borewells